



Geoscience LTD
LABORATORY TESTING DIVISION

6260-B Marindustry Drive

San Diego, CA 92121

PROPERTY CERTIFICATION

DATE: June 22, 2006

CLIENT: Thermilate Europe Limited
Northumberland Street
Huddersfield HD1 1RL

MATERIAL INVESTIGATED:

Thermilate Barrier Coating "E-Coat"

PROPERTY MEASURED:

Solar Reflectivity

MEASUREMENT METHOD:


ASTM E-1918; 3' x 3' coated roof samples or outer building wall panels tested under the sun. The procedures of ASTM E-1918 are similar to those of the CEC shading coefficient test method under Title 25 (Chapter 1, Subchapter 1, Article 5).

RESULTS:*

Solar Reflectivity = 0.872 (average of a number of tests during mid morning to mid afternoon)



*Details of the investigation are not included in this Property Certification; the results presented here apply only to the samples tested.


CERTIFYING OFFICER H.F. Poppendiek